

# SKG-IKOB PRODUCTCERTIFICATE

## 514.633.02

Date of issue: 05-02-2018



### Certificate holder

iLOQ Oy  
Yrttpellontie 10  
FL-90230 Oulu  
T: +358 (0) 40 3170 200  
E: info@iloq.com  
I: www.iloq.com



### Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

#### cylinder rose

delivered under logo / brand:

#### Iloq

delivered under type- and / or article number:

#### A10.79/78

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized, cursive script.

ir. H.A.J. van Dartel  
Certification manager

Verify at [www.sterrenwijzer.nl](http://www.sterrenwijzer.nl) if this certificate is still valid and actual.  
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
info@skgikob.nl  
www.skgikob.nl

**1. PRODUCT**  
cylinder rose

**PRODUCT TYPE**  
security furniture

---

## 2. TECHNICAL SPECIFICATION

Operating: N.A.  
Construction: 1 set of an outside part and an  
inside part with mounting screws  
System: with hole for oval-cylinder  
Material: outside-/ and inside part: stainless steel  
Dimension: outside part: Ø 59x19/25/31 mm  
inside part 63x63x3 mm  
Fixing: 4x M6  
Intended use: wood, PVC, metal  
in combination with oval cylinder (cert.nr: 514.312.01) and  
(certified) rim locks on doors

---

## 3. DELIVERY

The delivery includes an installation instruction:  
M004121\_A

---

## 4. PERFORMANCES

A cylinder rose according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this cylinder rose is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 3 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this cylinder rose is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
-